



# CLINTON UTILITIES BOARD

## 2010 WATER QUALITY REPORT

Clinton Utilities Board (CUB) is pleased to provide you with this Consumer Confidence Report announcing that the water we treat and distribute meets or exceeds all federal and state requirements. At CUB's award-winning water treatment plant thousands of tests are performed annually in order to ensure that all CUB customers are provided safe, high-quality drinking water. We are proud of our history of providing high-quality drinking water and are committed to maintaining this level of excellence.

The table included in this Report displays the results of our monitoring for the period of January 1, 2009 to December 31, 2009. All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. It is important to remember that the presence of contaminants does not necessarily indicate that water poses a health risk.

The source of the drinking water CUB treats and distributes is the Clinch River, a "surface water" supply. The Tennessee Department of Environment and Conservation (TDEC) has prepared a Source Water Assessment Program (SWAP) Report for our section of the Clinch River. The SWAP Report assesses the susceptibility of our untreated water source to *potential* contamination. Tennessee's water sources have been rated as "reasonably susceptible", "moderately susceptible" or "slightly susceptible" based on geologic factors and human activities in the vicinity of the water source. Our section of the Clinch River has been rated by TDEC as "reasonably susceptible" to *potential* contamination.

An explanation of Tennessee's Source Water Assessment Program, the SWAP summaries, susceptibility scorings and the overall TDEC report to EPA can be viewed online at [www.state.tn.us/environment/dws/dwassess.shtml](http://www.state.tn.us/environment/dws/dwassess.shtml) or you may contact Clinton Utilities Board to obtain copies of the Lower Clinch Watershed assessment.

### Information for Consumers At Risk

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly and infants can be particularly at risk from infections. These people should seek advice from their health care providers about not only their drinking water, but food preparation, personal hygiene, and precautions in handling infants and pets. EPA/Centers for Disease Control guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbiological contaminants are available from the Safe Drinking Water Hotline (1-800-426-4791).

### Contact Information

- For more information about contaminants and potential health effects, call the EPA's Safe Drinking Water Hotline at 1-800-426-4791.
- For more information about CUB's water, contact CUB's Water Department at 457-9232.

CUB's Board meets on a monthly basis. Information about regularly scheduled meetings can be obtained by calling CUB.



# Water Quality Data

## What does this chart mean?

- **AL** - Action Level, or the concentration of a contaminant which, when exceeded, triggers treatment or other requirements which a water system must follow.
- **MCL** - Maximum Contaminant Level, or the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology. To understand the possible health effects described for many regulated constituents, a person would have to drink 2 liters of water every day at the MCL level for a lifetime to have a one-in-a-million chance of having the described health effect.
- **MCLG** - Maximum Contaminant Level Goal, or the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.
- **MRDL** - Maximum Residual Disinfectant Level, or the highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for the control of microbial contaminants.
- **MRDLG** - Maximum Residual Disinfectant Level Goal, or the level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.
- **NTU** - Nephelometric Turbidity Unit is a measure of the clarity of water. Turbidity in excess of 5 NTU is just barely noticeable to the average person.
- **ppb** - Parts per billion which equals micrograms per liter - explained as a relation to time and money as one part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.
- **ppm** - Parts per million which equals milligrams per liter (mg/l) - explained as a relation to time and money as one part per million corresponds to one minute in two years or a single penny in \$10,000.
- **TT** - Treatment Technique, or a required process intended to reduce the level of a contaminant in drinking water.

Contaminant	Violation Yes/No	Level Found	Range of Detections	Date of Sample	Unit Measurement	MCLG	MCL	Likely Source of Contamination
Total Coliform Bacteria	No	0		2009		0	<5% of samples	Naturally present in the environment
Turbidity <sup>1</sup>	No	0.13	0.03 -0.13	2009	NTU	N/A	TT	Soil runoff
Copper <sup>2</sup>	No	90 <sup>th</sup> %= 0.16		2007	ppm	1.3	AL=1.3	Corrosion of household plumbing systems
Fluoride	No	1.10	0.79-1.10	2009	ppm	4	4	Erosion of natural deposits; water additive
Lead <sup>2</sup>	No	90 <sup>th</sup> %= 4.2		2007	ppb	0	AL=15	Corrosion of household plumbing systems, erosion of natural deposits
Sodium	No	10.0		2009	ppm	N/A	N/A	Erosion of natural deposits; used in some home water treatment systems
Total Trihalomethanes (TTHM)	No	59 avg.	20-76	2009	ppb	N/A	80	By-product of drinking water chlorination
Haloacetic Acids (HAA5)	No	39 avg.	14-59	2009	ppb	N/A	60	By-product of drinking water disinfection
Total Organic Carbon <sup>3</sup>	No			2009	ppm	TT	TT	Naturally present in the environment
Chlorine	No	1.54 avg.	0.5-2.2	2009	ppm	MRDLG 4	MRDL 4	Water additive used to control microbes

<sup>1</sup> Turbidity is a measure of the cloudiness of the water. CUB monitors turbidity because it is a good indicator of the effectiveness of our filtration system. 100% of our samples were below the turbidity limit of 0.3 NTU.

<sup>2</sup> During the most recent round of Lead and Copper testing, none of the 32 households sampled contained concentrations exceeding either the Lead Action Level or the Copper Action Level. If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. CUB is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

<sup>3</sup> CUB met the treatment technique requirements for Total Organic Carbon.